

QUALITY CERTIFICATE

JP 551 FR

Malmö 2016-03-02

Manufacturer declaration of conformity.

We hereby confirm that the goods are of harmonized standard.

Please see attached **TECHNICAL SPECIFICATIONS FOR DUCTING MATERIAL**.

TECHNICAL SPECIFICATIONS FOR DUCTING MATERIAL JP551FR

| | |
|-------------------------------|------------------------------|
| JP 551 FR | |
| Fabric: | PE 1100 Dtex |
| Construction: | Knitted 12x12/inch |
| Total weight: | Minimum 550 g/m ² |
| Weight test: | DIN 53 352 |
| Tensile strength: | 1700/1700 N/5 cm |
| Tensile test: | DIN 53 354 |
| Tear strength: | 400/400 N |
| Tear test: | DIN 53 363 |
| Welding seam strength: | 1550 N/5 cm |
| Adhesive test: | Min 100 N/5 cm DIN 53 357 |
| Frost-resistance: | -20° C |
| Heat-resistance: | +70° C |
| Flame Retardency: | FR EN 13501-1, B-s2.d0 |

Tested according to ISO 11925-2:2010 for Flame retardant.

Bill Jönsson
Production Manager
JP Jensen Ventilation AB