

# QUALITY CERTIFICATE

**JP 753 FR**

Malmö 2016-03-02

## Manufacturer declaration of conformity.

We hereby confirm that the goods are of harmonized standard.

Please see attached **TECHNICAL SPECIFICATIONS FOR DUCTING MATERIAL**.

### **TECHNICAL SPECIFICATIONS FOR DUCTING MATERIAL JP753FR**

<b>JP 753 FR</b>	
<b>Fabric:</b>	PE 1430 x 2200 Dtex
<b>Construction:</b>	Coated 20 x 20/inch
<b>Total weight:</b>	Minimum 750 g/m <sup>2</sup>
<b>Weight test:</b>	DIN 53 352
<b>Tensile strength:</b>	2350/2550 N/5 cm
<b>Tensile test:</b>	DIN 53 354
<b>Tear strength:</b>	500/700 N
<b>Tear test:</b>	DIN 53 363
<b>Welding seam strength:</b>	2200 N/5 cm
<b>Adhesive test:</b>	Min 100 N/5 cm DIN 53 357
<b>Frost-resistance:</b>	-20° C
<b>Heat-resistance:</b>	+70° C
<b>Flame retardancy:</b>	FR EN 13501-1, B-s2.d0

Tested according to ISO 11925-2:2010 for Flame retardant.

Bill Jönsson  
Production Manager  
JP Jensen Ventilation AB